CITY OF BREMERTON PUBLIC WORKS AND UTILITIES

WATER STANDARD DETAILS

TABLE OF CONTENTS

| GENERAL COMMENTS | 5000 |
|--|--|
| WATER METERS 500° | 1-5029 |
| 1" X 3/4" Domestic/Irrigation service connection 1" x 1" Domestic/Irrigation service connection 1 1/2" and 2" Domestic/Irrigation service connection 3" to 10" compound water meter with by-pass 3" to 10" Turbine Meter Installation with by-pass | 5001 5002 5003 5005 5008 |
| BACKFLOW PROTECTION 503 | 0-5059 |
| 2 to 10 Fire Sprinkler Serv Conn Dbl Chk Valve Assy or Dbl Chk Detector Assy Below Ground Dbl Chk Valve Assy or Det. Assy RPDA RPBA Above Ground 3-4 to 10 (DCVA, DCVA, RPDA) Inside 3 4 to 1-1 2 Outside Double Check Valve 3-4 to 1 1-2 Reduced Pressure Backflow Assembly 3/4" to 2" Outside Installed Irrigation or Fire Sprinkler DCVA 3/4" to 2" And smaller RPBA with Protective Cover 3" to 10" (RPBA) Above Ground Installation | 5034 5035 5036 5038 5039 5040 5041 5042 5043 |
| PRESSURE REDUCING VALVE ASSEMBLY (PRVA) 5060 | 0-5079 |
| 3" to 10" Pressure Reducing Valve Station Domestic Water Service Standard PRV | 5060 5075 |

| FIRE HYDRANTS | 5080-5085 |
|---|------------------------------|
| Fire hydrant detail Valve marker post Guard post Fire hydrant marker placement detail | 5081 5082 5083 5084 |
| VALVE OPERATION | 5100-5149 |
| Cast iron valve box assembly | 5120 |
| | |
| WATER MAIN BLOW-OFF AND FLUSH PROCEDURES | 5200-5299 |
| 2" blow-off assembly Typical Installation Hydro-Guard HG-4 flushing system Hydro-Guard Vertical unit HG-5 air flushing system | 5201 5205 5210 |
| AIR VAC DETAILS | 5300-5325 |
| 1" air and vacuum release valve assembly 2" air and vacuum release valve assembly 12" mains | 5315 5320 |
| PIPE LAYING DETAILS | 5326-5399 |
| Casing installation Water main slope anchors | 5330 5331 |